

PUBLIC NOTICE

FAILURE TO MONITOR TOTAL COLIFORM BACTERIA

This notice is to inform users of the Copper Mountain Ranch water system, PWS#11-328, that the water system failed to monitor for total coliforms in the month(s) of November and December and therefore cannot be sure of the quality of water during that time. Tests of the RO System only came back for positive for Coliform in November and Coliform /E Coli in December.

The water system is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

Total coliforms: *“Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.”*

The water system has disinfected and conducted follow up tests in December resulting in negative results for Coliform and E Coli to correct the problem.

For more information, please contact the Public Works Department at (520) 421-8625.

Please share this information with other people that drink the water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Any ADEQ translation or communication in a language other than English is unofficial and not binding on the State of Arizona.

Cualquier traducción o comunicado de ADEQ en un idioma diferente al inglés no es oficial y no sujetará al Estado de Arizona a ninguna obligación jurídica.

This notice is being posted by the City of Casa Grande Public Works Department.

State Water System ID# 11-328.

Date: February 23, 2016